
Energy performance certificate (EPC)				
Holy Trinity Church Hall Kilwardby Street ASHBY-DE-LA-ZOUCH LE65 2FR	Energy rating	Valid until: 24 April 2033 Certificate number: 2402-5304-0870-1034-0348		
Property type		Non-residential Institutions: Education		
Total floor area		253 square metres		

## Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

### Energy efficiency rating for this property

This property's current energy rating is D.



Properties are given a rating from A+ (most efficient) to G (least efficient).

Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

### How this property compares to others

Properties similar to this one could have ratings:

بالتنظ بالبيمط ال

https://find-energy-certificate.service.gov.uk/energy-certificate/2402-5304-0870-1034-0348?print=true

001.0



If typical of the existing stock

# Breakdown of this property's energy performance

Main heating fuel	Natural Gas	
Building environment	Heating and Natural Ventilation	
Assessment level	3	
Building emission rate (kgCO2/m2 per year)	44.57	
Primary energy use (kWh/m2 per year)	271	

## **Recommendation report**

Guidance on improving the energy performance of this property can be found in the <u>recommendation report (/energy-certificate/5453-9680-6549-9614-9404</u>).

## Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

#### **Assessor contact details**

Assessor's name	Justin Clements
Telephone	0800 170 1201
Email	admin@easyepc.org

#### Accreditation scheme contact details

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor ID	EES/025698
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

### **Assessment details**

Employer	EASY EPC
Employer address	12 Albion Street Brighton BN2 9NE
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	17 April 2023
Date of certificate	25 April 2023