



BARSBY LIGHTNING PROTECTION

The Cottage, Shuttleworth Grange,
Shuttleworth Lane, Cosby, Leicester LE9 1RF
Tel: 01455 208229 Mobile: 07798 751051

Certificate of Compliance for Earth Installations & Lightning Conductors.

This is to certify that the structure known as

Holy Trinity Church
ASHB-DE-LA-ZOUCH
LEICESTERSHIRE

was electrically tested on

25. JANUARY. 2024

and was subsequently found to be in accordance with the
British Standard Code of Practice NF C17-102 and BSEN62305.

OVERALL FULLY COMPLETED READING

*This Certificate applies to the Earth Installations only,
from earth electrode to test clamp height only.*

= 8.34 OHMS.

Expiry Date

24.1.2025

C.J. Barsby

CITB & CSCS Registered Engineer